

1. **Unique Product Identification Code:** Firescreen EW - SN: 00000
2. **Intended Use:** Self-closing, space enclosure textile fire curtain with limited radiation for reveal and wall-mounting
3. **Manufacturer:** SIMON PROtec Systems GmbH
 Manufacturer address: Medienstraße 8
 D-94036 Passau
 Germany
4. **System assessment:** System 1
5. **Notified body:** MPA Braunschweig
Notified Body Number: 0761
EC Certificate Number: 0761-CPR-0846
Harmonized Standard: EN 16034:2014
6. **Declaration of Performance:**

Essential Characters:	Declared Performance:
Clear opening	8250 x 6000 mm
Resistance to fire	E 120 EW 90
Ability to release	released
Self-Closing	C
Durability of ability to release	Release maintained
Durability of self-closing - against degradation (cycles) - against ageing (corrosion)	2 (achieved)

The performance of the product identified in point 1 is in conformity with the declared performances in point 6. This declaration of performance is issued under the sole responsibility of the manufacturer identified in point 3.

MPA Braunschweig, Beethovenstr. 52, 38106 Braunschweig, Germany

Certificate of constancy of performance

0761 – CPR – 0846

In compliance with Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011 (the Construction Product Regulation or CPR), this certificate applies to the construction product

**Fire protection curtain with a size up to 8.25 m x 6.00 m
with the trade name 'Firescreen EW'
Classification according to EN 13501-2: E120, EW90, C2**

produced by or for

**SIMON PROtec Systems GmbH
Medienstraße 8
94036 Passau
Germany**

in the manufacturing plant

Factory 2.

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard

EN 16034:2014 i.V.m. EN 13241:2003+A2:2016

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the

constancy of performance of the construction product.

This certificate has first been issued on 2020-02-20. It is valid from 2021-01-01 and will remain valid till 2025-12-31, as neither the harmonised specification, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the product certification body.

Braunschweig, 2021-07-15

Z-3/1161/11



Dr.-Ing. W. Hinrichs
Head of certification